

SHORE POWER CHECKLIST

TO CONNECT TO OUR SHORE POWER YOUR LEAD MUST BE COMPLIANT :

- Heavy duty outdoor-rated lead (min 2.5mm round cable)
- Weatherproof locking collar fitted to the shore power end of your lead
- Lead Tested & Tagged annually - ensure tag is visible on the shore power end

If you answered NO to any of the above, please update your lead as soon as possible. See our price list below. We have loan leads available while you update your lead.



ARE YOU EXPERIENCING A POWER SUPPLY ISSUE?

Please follow this troubleshooting checklist before we engage our Marina Electrician to investigate the outage.

- Check if the Safety Switch (circuit breaker/RCD) has tripped. If so, pull open the door on the power pillar and reset the tripped switch.
- IF your lead is fully compliant (see above) try plugging into another shore power socket (if one is available).
- What is drawing power (fridge, air con, batteries charging?). Try turning all off/unplugging and turning ONE back on at a time.
- Are the pins on your corroded? We suggest cleaning with emery paper (wet 'n dry).



If all above completed & problem not resolved, please contact the Marina Office and we will arrange an inspection.

PRICE LIST (incl GST)

Supply New Lead with Collar (includes Test & Tag)

15m 10 amp with male collar	\$140	Supply & Fit Collar to Existing Lead (incl Test & Tag)	\$95
20m 10 amp with male collar	\$150	Supply Collar only - Male (10 amp or 15 amp)	\$40
15m 15 amp with male collar	\$160	Supply Collar only - Female (10 amp or 15 amp)	\$50
20m 15 amp with male collar	\$170	Test & Tag Existing Lead	\$30